

---

## Special Provision to Special Specification 6154 Aluminum Electrical Conductors

---



Special Specification 6154 "Aluminum Electrical Conductors," is amended with respect to the clauses cited below. No other clauses or requirements of this Item are waived or changed.

**Article 6154.2.1, "Materials"**. The first paragraph is voided and replaced by the following:

**Conductor.** Ensure that equipment grounding conductors size AWG No. 8 and larger are stranded copper, except for the grounding electrode conductor, which will be a solid copper conductor. Aluminum conductors may be used as equipment grounding conductors only if they contain no terminations located underground or within 18 in. of the earth. Aluminum equipment grounding conductors must be insulated. Do not use bare aluminum conductors.