

---

# Special Provision to Special Specification 6391

## LED Decorative Illumination Assembly

---



Special Specification 6391, "LED Decorative Illumination Assembly" is amended with respect to the clauses cited below. No other clauses or requirements of this Item are waived or changed.

**Article 6391.2., "Materials."** Adds the following Standard Specification Item to the paragraph's list:

- Item 416, "Drilled Shaft Foundations."

**Section 6391.2.2., "Pole Options."** The following LED decorative illumination assembly option is added:

- e) **LED Decorative Illumination Assembly 8'-8' Dual Arms – 250W**

**Section 6391.2.3.1., "General Requirement."** Replaces first sentence with:

Provide a decorative LED luminaire with a minimum of 17,300 lumens for the 250W LED, a minimum of 12,000 lumens for the 100W LED, a minimum of 5,000 lumens for the 50W LED, maximum 3000K CCT, and "dark sky" compliant shielding.

**Section 6391.2.3.1., "General Requirement."** Replaces last sentence with:

Lighting should be 250W LED EQ, 100W LED EQ, or 50W LED EQ.

**Article 6391.5., "Payment."** Adds at the end of the first paragraph:

"...or LED Decorative Illumination Assembly 8'-8'-250W."

**Article 6391.5., "Payment."** Replaces the first sentence of the last paragraph with:

"New drilled shaft foundations will be paid under Item 416, "Drilled Shaft Foundations."