
Special Provision to Special Specification 7017

Sanitary Sewers



Special Specification 7017 "Sanitary Sewers," is amended with respect to the clauses cited below. No other clauses or requirements of this Item are waived or changed.

Section 2.2.1., "Gravity Sewer," is replaced by the following:

2.2.1 **Gravity Sewer.** Provide plastic pipe and fittings meeting the requirements of D3034 SDR26.

Section 2.2.2., "Force Mains," is replaced by the following:

2.2.2 **Force Mains.** Provide PVC pipe for force mains meeting or exceeding the requirements of AWWA DR-18 (white). Use ductile-iron (Class 52) fittings for force main pipes.

Provide sanitary sewer force mains crossing the roadway with restrained joints (Certa-Lok or approved equal) the full length of the crossing, from existing connection to existing connection. Include the cost in the unit price bid for the various size of pipes installed. No separate pay item will be allowed, as this is subsidiary to installing sanitary sewers.