
Special Provision to Item 764

Pump Station and Drainage System Cleaning



Item 764, "Pump Station and Drainage System Cleaning" of the Standard Specifications is amended with respect to the clauses cited below. No other clauses or requirements of this Item are waived or changed.

Article 764.1., "Description," is voided and replaced by the following:

764.1. Description. Perform hydraulic cleaning of septic tanks, vacuum removal and disposal of debris in drain inlets, pump station wells, basket and inlet piles, downspouts, sumps, storm sewers, and slotted drains.

Article 764.3., "Equipment," The following paragraph is added at the beginning of this article:

For septic tanks cleaning and maintenance, provide a septic truck with a high pressure water pump capable of pumping at least 35 gpm/2,000 psi with at least 40 ft. of hose and water storage tank with at least 500 gal. capacity and a vacuum pump with a 5 hp. Motor, or as approved. Dispose of wastewater in accordance with the Texas Commission on Environmental Quality standards. Provide clean water for the storage tanks at the site.

Article 764.4., Work Methods." The following section is added:

764.4.8. Septic Tanks. Clean septic tank at Martha Lights Viewing Rest Area.

Article 764.6., "Payment," is voided and replaced with the following:

764.6. Payment. The work performed and materials furnished in accordance with this item and measured as provided under "Measurement" will be paid for at the unit price bid for "Drain Inlet Cleaning," "Pump Station Well Cleaning," "Basket and Inlet Pipe Cleaning," "Downspout Cleaning," "Sump Cleaning," "Storm Sewer Cleaning," of the type and size specified for "Slotted Drain Cleaning" and "Septic Tank Cleaning." This price is full compensation for cleaning, removing, and disposing of debris, wash water and wastewater, equipment, labor, materials, and incidentals.