






DISCLAIMER: The use of this standard is governed by the "Texas Engineering Practice Act". No warranty of any kind is made by TxDOT for any purpose whatsoever. TxDOT assumes no responsibility for the conversion of this standard to other formats or for incorrect results or damages resulting from its use.

DATE: FILE:



(Bearing surface must be clean and free of all loose material before placing bearing pad.)

- Quantities shown are based on an "H" value of 36'. For each linear foot variation in "H" value, make the following adjustments:
Bars V length, 1'-0"
Bars Z length, 31'-5"
Reinforcing steel, 165 Lb
Class "C" conc (col), 0.78 CY
- This standard may not be used for "H" heights exceeding 36'. In areas of very soft soil or where scour is anticipated, allowable "H" heights must be evaluated by the Engineer prior to the use of this standard.
- Omit Dowels D at end of multi-span units. Adjust reinforcing steel total accordingly.
- Foundation Loads based on "H" = 36'.
- Measured parallel to top of cap cross-slope.

TABLE OF ESTIMATED QUANTITIES (1)

Bar	No.	Size	Length	Weight
A	7	#11	30'-6"	1,134
B	6	#11	29'-0"	924
D (3)	4	#9	1'-8"	23
S	40	#5	13'-8"	570
T	10	#5	29'-0"	302
U	2	#5	9'-8"	20
V	30	#9	38'-9"	3,953
Z	3	#4	1154'-7"	2,314
Reinforcing Steel				Lb 9,240
Class "C" Concrete (Cap)				CY 13.9
Class "C" Concrete (Col)				CY 28.3

FOUNDATION LOADS (4)

Span Average	Drilled Shaft Loads	Pile Load (Tons/Pile)		
		3 Pile Ftg	4 Pile Ftg	5 Pile Ftg
Ft	Tons/Shaft			
40	111	40	31	25
45	119	43	33	27
50	128	46	35	29
55	136	49	37	30
60	144	51	39	32
65	152	54	41	34
70	160	57	43	35
75	168	59	45	37
80	176	62	47	38
85	184	65	49	40
90	192	67	51	42
95	200	70	53	43
100	208	73	55	45
105	216	75	57	46
110	224	78	59	48
115	232	81	61	50
120	240	83	63	51

GENERAL NOTES:

Designed according to AASHTO LRFD Bridge Design Specifications. See Bridge Layout for foundation type, size and length. See Common Foundation Details (FD) standard sheet for all foundation details and notes. See Shear Key Details (IGSK) standard sheet for all shear key details and notes, if applicable. Bent selected must be based on the average span length rounded up to the next 5 ft increment. Details are drawn showing right forward skew. See Bridge Layout for actual skew direction. These bent details may be used with standard SIG-30-15 only.

Cover dimensions are clear dimensions, unless noted otherwise. Reinforcing bar dimensions shown are out-to-out of bar.

MATERIAL NOTES:

Provide Class C concrete (f'c = 3,600 psi). Provide Class C (HPC) concrete if shown elsewhere in the plans. Provide Grade 60 reinforcing steel. Galvanize dowel bars D.

HL93 LOADING



INTERIOR BENTS
TYPE TX28 THRU TX54
PRESTR CONC I-GIRDERS
30' ROADWAY 15° SKEW

BIG-30-15

FILE: IG-BIG3015-17.dgn	DN: TAR	CK: SDB	DW: JTR	CK: TAR
©TxDOT August 2017	CONT	SECT	JOB	HIGHWAY
REVISIONS	DIST	COUNTY	SHEET NO.	