DISCLAIMER:
The use of this standard is governed by the "Texas Engineering Practice Act." No warranty of any kind is made by TxDOT for any purpose whatsoever.
TxDOT assumes no responsibility for the conversion of this standard to other formats or for incorrect results or damages resulting from its use.

WALL SUMMARY

MSE Retaining Wall	Begin Station (1)	End Station (1)	Retained Soil Friction Angle (2)	Foundation Soil Friction Angle (2)	Ground Improvement (3)	Min Earth Reinf. Length (4)	Min Wall Embedment (5)	Underdrain Required (6)	Drawdown Analysis (7)	Bench Width (8)



TYPICAL SECTION

(Rapid drawdown condition.)

(1) Indicate limits for which the stated soil design requirements and assumptions are applicable.

(2) Base the listed retained and foundation friction angle on local experience or measured/correlated long term strength values.

(3) Indicate if ground improvement is required or not required. If shown as required, refer to ground improvement detail(s) shown elsewhere in the plans for additional information.

(4) Indicate on table both the minimum length and length ratio required. The minimum default length of earth reinforcements is either 8 feet or 70% of the wall height, whichever is greater. Wall height and design wall height may differ depending on project geometry and loading conditions. Note: Wall height at bridge abutments is equal to the distance between the top of leveling pad and finished grade at the bridge abutment backwall.

(5) Guidance to wall designer of record for determination of minimum wall embedment. Unless noted elsewhere in the plans, provide a minimum embedment from the top of leveling pad to finish grade of
- 1 foot for level ground where there is no potential for erosion or future excavation, or
- 2 feet for sloping ground (4.0H:1.0V or steeper) or where there is potential for removal of soil in front of the wall.

(6) Indicate if underdrain is required or not required.

(7) Indicate if rapid drawdown analysis is required.

(8) Horizontal bench width at base of wall varies. Use the following criteria to establish base width:
    A = 2-foot Min for $X > 4$ or
    A = 4-foot Min for $X \leq 4$
    Applicable to both drawdown and dry condition.

SPECIAL NOTES:
This sheet is to be filled out by the wall designer of record at time of plan preparation to provide soil strength parameters for the design of the specified walls.
The completed sheet must be signed, sealed, and dated by a licensed Professional Engineer.

Texas Department of Transportation | Bridge Division Standard

MECHANICALLY STABILIZED EARTH RETAINING WALL DESIGN DATA

RW(MSE)DD

FILE: RW-MSEDD-22.dgn	DN: TxDOT	CK: RLE	DW: JER	CK: RLE
©TxDOT June 2022	CONT	SECT	JOB	HIGHWAY
REVISIONS				
	DIST	COUNTY	SHEET NO.	

DATE:
FILE: