




DISCLAIMER: The use of this standard is governed by the "Texas Engineering Practice Act". No warranty of any kind is made by TxDOT for any purpose whatsoever. TxDOT assumes no responsibility for the conversion of this standard to other formats or for incorrect results or damages resulting from its use.




TWO-PAD DETAIL PLAN
(At abutment or inverted-T cap or at interior bent)




TWO-PAD DETAIL SKEW PLAN
(At abutment or inverted-T cap)




TWO-PAD DETAIL SKEW PLAN
(At interior bent)



ONE-PAD DETAIL PLAN
(At abutment or inverted-T cap or at interior bent)




ONE-PAD DETAIL SKEW PLAN
(At abutment or inverted-T cap)



ONE-PAD DETAIL SKEW PLAN
(At interior bent)

ELASTOMERIC BEARING PAD PLACEMENT AND BEAM END DIAGRAMS

Place one bearing pad at forward station beam end.
Place two bearing pads at back station beam end.



LAMINATED ELASTOMERIC BEARING PAD
(50 DUROMETER)

- ① Maximum and minimum layer thicknesses shown are for elastomer only, on tapered layers.
- ② Indicate BEARING TYPE on all pads. For tapered pads, locate BEARING TYPE on the high side. The Fabricator must include the value of "N" (amount of taper in 1/8" increments) in this mark.
Examples: N=0, (for 0" taper)
N=1, (for 1/8" taper)
N=2, (for 1/4" taper)
(etc.)
Fabricated pad top surface slope must not vary from plan beam slope by more than $(\frac{0.0625}{\text{Length}})$ IN/IN.
- ③ Locate permanent mark here.

TABLE OF BEARING PAD DIMENSIONS (ALL PRESTR CONC SLAB BM TYPES)

One-Pad (Ty SB1-"N") ②			Two-Pad (Ty SB2-"N") ②		
W	L	T	W	L	T
14"	7"	2"	7"	7"	2"

Pad sizes shown are applicable for the following conditions:

- (1) All one, two and three span units where the minimum span length is not less than 25' and the maximum span is not more than 50'.
- (2) Skews less than or equal to 30°.

GENERAL NOTES:

These details accommodate skew angles up to 30°. Shop drawings for approval are required. A bearing layout which identifies location and orientation of all bearings must be developed by the bearing fabricator. Permanently mark each bearing in accordance with the bearing layout. A copy of the bearing layout is to be provided to the Engineer. Cost of furnishing and installing elastomeric bearings must be included in unit price bid for "Prestressed Concrete Slab Beams".

HL93 LOADING

		Bridge Division Standard	
ELASTOMERIC BEARING AND BEAM END DETAILS			
PRESTR CONCRETE SLAB BEAM			
PSBEB			
FILE: psbste06-17.dgn	DN: TxDOT	CK: TxDOT	OW: TxDOT
©TxDOT January 2017	CONT	SECT	JOB
REVISIONS		HIGHWAY	
DIST		COUNTY	SHEET NO.

DATE: FILE: